

Number	20-001867-PR03 (NW-A01-020310-en-01)
Owner	GEALAN Fenster-Systeme GmbH Hofer Str. 80 95145 Oberkotzau Germany
Product	Double tilt and turn casement door with opening meeting stile
Designation	System: GEALAN-LINEAR
Details	Manufacturer GEALAN Fenster-Systeme GmbH, -Oberkotzau; Material Polyvinyl Chloride unplasticized (PVC-U) anthracite; Type of opening Turn / tilt and turn; Opening direction Active casement DIN right (opening) to the inside, inactive casement DIN left (opening) to the inside; Overall dimensions (W x H) 1910 mm x 2348 mm
Special features	Watertightness was carried out with additional floor simulation (reduced water level).

Result

Requirements according to ift-Guideline VE-08/4:2017-03 fulfilled (requirements according to RAL-GZ 716:2013-04 were hereby covered)

Air permeability according to EN 12207:2016-12	Resistance to wind load according to EN 12210:2016-03	Watertightness according to EN 12208:1999-11	Behaviour between different climates - Designs being sensitive to deformation	Operating forces according to EN 13115:2001-07	Mechanical properties according to EN 13115:2001-07	Determination of the tightness of the corner joint according to ift-Richtlinie FE-13/1 2011-04
						
4	C2/B3	9A	fulfilled	1	4	fulfilled

ift Rosenheim

22.12.2020

Thomas Krichbaumer

Thomas Krichbaumer
Deputy Head of Testing Department
Building Component Testing

D. Gromotka

Daniel Gromotka, B.Eng.
Operating Testing Officer
Building Component Testing

Basis *)

ift-Richtlinie FE-13/1:2011-04

EN 14351-1:2006+A2:2016-09

*) and corresponding national versions (e.g. DIN EN)

Test report: 20-001867-PR03 PB-A01-020310-de-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 993-5BEA4