

ift-Nachweis

Classification Report



Number	20-001867-PR04 (NW-A01-0203-en-01)
Owner	GEALAN Fenster-Systeme GmbH Hofer Str. 80 95145 Oberkotzau Germany
Product	Tilt and turn window with fixed sublight
Designation	System: GEALAN-LINEAR
Details	Manufacturer GEALAN Fenster-Systeme GmbH, - Oberkotzau; Material Polyvinyl Chloride unplasticized (PVC-U) white; Type of opening Tilt and turn; Opening direction DIN right, inward opening; Overall dimensions (W x H) 1576 mm x 2376 mm
Special features	

Result

Air permeability according to EN 12207:2016-12	Resistance to wind load according to EN 12210:2016-03	Watertightness according to EN 12208:1999-11	Operating forces according to EN 13115:2001-07	Mechanical properties according to EN 13115:2001-07
				
4	C4/B4	9A	1	4

ift Rosenheim
16.10.2020

Thomas Krichbaumer

Thomas Krichbaumer
Deputy Head of Testing Department
Building Component Testing

D. Gromotka
Daniel Gromotka, B.Eng.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09

*) and corresponding national versions
(e.g. DIN EN)

Test report: 20-001867-PR04 PB-A01-0203-de-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: F0B-D05DD