

Number	20-001867-PR05 (NW-A01-02-en-01)
Owner	GEALAN Fenster-Systeme GmbH Hofer Str. 80 95145 Oberkotzau Germany
Product	Double tilt and turn window with opening meeting stile
Designation	System: GEALAN-LINEAR
Details	Manufacturer GEALAN Fenster-Systeme GmbH,- Oberkotzau; Material Polyvinyl Chloride unplasticized (PVC-U) white; Type of opening Turn / tilt and turn; Opening direction Active casement DIN right (opening) to the inside, inactive casement DIN left (opening) to the inside; Overall dimensions (W x H) 2884 mm x 1176 mm
Special features	

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C4/B4

Watertightness according to EN 12208:1999-11



Class: 9A

Basis *)

EN 14351-1:2006+A2:2016-09

*) and corresponding national versions (e.g. DIN EN)

Test report: 20-001867-PR05 PB-A01-02-de-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

14.10.2020

Thomas Krichbaumer

Thomas Krichbaumer
Deputy Head of Testing Department
Building Component Testing

D. Gromotka

Daniel Gromotka, B.Eng.
Operating Testing Officer
Building Component Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: C24-68255